

NEW BUSINESS

1-21-09


AMORY ENGINEERS, P.C.

WATER WORKS • WATER RESOURCES • CIVIL WORKS

25 DEPOT STREET, P.O. BOX 1768
DUXBURY, MASSACHUSETTS 02331-1768

TEL.: 781-934-0178 • FAX: 781-934-6499
WWW.AMORYENGINEERS.COM

January 7, 2009



RE Chapman Company
30 North Main Street
West Boylston, MA 01583

Subject: **Redevelopment of East Main Street Well #2, Middleborough, MA**

Gentlemen:

This letter is to advise you that the Middleborough Town Manager has awarded the subject project to you based on your bid of \$29,755. Tabulation of Bids is enclosed for your information.

In order to expedite signing of the Agreement, we have enclosed one complete set of the Contract Documents and four copies of pages 00500-1, -21 and -23 of the Agreement and pages 00610-1 through -7 of the Contract Bonds. Please complete the appropriate pages and return all copies to this office. Do not date pages 00500-1, 00610-1 through -5, as this will be done by the Town Manager when he signs the contract.

Also, five copies of your insurance certificates should be submitted. Your insurance carrier should pay particular attention to the requirements of Agreement Section A7 Insurance and Specials Conditions Section SC5 Limits for Insurance of the documents. In addition, we require that your insurance carrier provide a letter to the effect that the insurance furnished for the contract satisfies the requirements of these sections.

Please call if you have any question.

Very truly yours,

AMORY ENGINEERS, P.C.

By:

A handwritten signature in black ink, appearing to read "Richard S. Johnson".

Richard S. Johnson, P.E.

RSJ:vs

enc

cc: Charles J. Cristello ✓
Richard Tinkham

AMORY ENGINEERS, P.C.

WATER WORKS • WATER RESOURCES • CIVIL WORKS

25 DEPOT STREET, P.O. BOX 1768
DUXBURY, MASSACHUSETTS 02331-1768

TEL.: 781-934-0178 • FAX: 781-934-6499
WWW.AMORYENGINEERS.COM

December 30, 2008

Mr. Charles J. Cristello, Town Manager
10 Nickerson Avenue
Middleborough, MA 02346

Subject: **Redevelopment of East Main Street Well #2, Middleborough, MA**

Dear Mr. Cristello:

Sealed bids for the subject contract were opened on December 30, 2008. Four bids were received and are summarized on the enclosed Summary of Bids. The low two bids¹ in the amount of \$16,380 and \$17,690 did not provide for MBE/WBE participation or the minority manpower utilization. RE Chapman of West Boylston, MA submitted the third bid, in the amount of \$29,755 with MBE/WBE participation and minority manpower utilization provided. Based on discussions with Allison Ferreira we understand that the Town will be requesting advice from Town Counsel as to the responsiveness of the two low bidders, who did not meet Town requirements as part of their bid submittal².

Should the low two bidders be deemed non-responsive, we are satisfied that RE Chapman has the experience and capability to complete the contract. Copies of the appropriate sections of the documents will be forwarded to RE Chapman for completion upon direction from your office.

Please call if you have any question.

Very truly yours,

AMORY ENGINEERS, P.C.

By:



Richard S. Johnson, P.E.

RSJ:rsj

enc

cc: Richard Tinkham

¹ Submitted by Boart Longyear, of North Reading, MA and Maher Services of Stoneham, MA

² We have enclosed two sections from the contract (Information for Bidders and Bid Form); which specify what must be included as part of the Bid Submittal.

REDEVELOPMENT OF EAST MAIN STREET WELL #2

Anory Engineers, P.C.
25 Depot Street, PO Box 1768
Duxbury, MA 02331

MIDDLEBOROUGH WATER DIVISION, DPW

Bid Opening December 30, 2008

By: RSJ
Checked By: AR
Date: 12/30/2008

	RE Chapman Co. West Boylston, MA	Layne Christensen Company Draught, MA	Boart Longyear Company, Inc. North Reading, MA	Malter Services, Inc. Stoneham, MA
1 Mobilization and demobilization for conventional redevelopment of East Main Street Well #2	Lump Sum \$9,650.00	\$7,600.00	\$2,000.00	\$2,800.00
2 Removal and reinstallation of pumping unit at East Main Street Well #2	Lump Sum 6,500.00	8,950.00	5,050.00	5,000.00
3 Redevelopment by simultaneously surging and pumping the gravel-pack well, surging with chemicals as necessary and disinfection of the well on completion of redevelopment	60 hrs. 175.00	205.00	125.00	125.00
4 Inhibited hydrochloric acid	500 gals. 5.00	4.00	3.00	3.50
5 Phosphate	300 lbs. 1.75	3.00	1.00	2.00
6 Chlorine (HTH), 65 percent concentration	20 lbs. 4.00	10.00	1.50	2.00
Bidders's Total	\$29,755.00	\$31,950.00	\$16,380.00	\$17,690.00
Computed Total	\$29,755.00	\$31,950.00	\$16,380.00	\$17,690.00